

Fire Marshal List for Event Permits

Emergency plan to address and include the following:

- **Fire Apparatus access must be maintained. 2018 IFC 3106.2.3.1**
- **Access to all fire Hydrants and existing fire lanes must be maintained. 2018 IFC 3106.2.3.1**
- Side by side tents cannot aggregate more than 700 square feet, without a 12' fire break 2018 IFC 3103.2 *(Provide size of tents, will they have sides?)*
- **Provide tent locations on the site plan, including required fire access rows. 2018 IFC 3106.2.3**
- Cooking appliances or open flame shall not be used within 20' of a tent or 10' of a building. 2018 IFC 3106.5.1

Are generators to be used?

- o Every Generator must have a fire extinguisher provided. 2018 IFC 3106.6.3
- o Generators must be kept 20' away from tents. 2018 IFC 3107.16
- o Flammable or Combustible liquid storage must be in approved containers, and minimum 50' from tents. 2018 IFC 3107.14.1, 2018 IFC Chapter 57
- o Refueling must be performed at least 20' away from tents 2018 IFC 3107.14.3

Extinguishers must be accessible within 75 ' of any direction in the vendor area 2018 IFC Sec 906. Note extinguisher locations on the plan.

IFC 2018 403.12.2 Provide a public Safety plan, to address:

- o 1. Emergency vehicle ingress and egress.
- o 2. Fire protection.
- o 3. Emergency egress or escape routes.
- o 4. Emergency medical services.
- o 5. Public assembly areas.
- o 6. The directing of both attendees and vehicles, including the parking of vehicles.
- o 7. Vendor and food concession distribution.
- o 8. The need for the presence of law enforcement.
- o 9. The need for fire and emergency medical services personnel.
- o 10. The need for a weather monitoring person